

Vendor Displays with with Roofs or Tenting

Roofs and tenting interferes with
the fire sprinkler system



Single story structure with a roof

- Roof covering exceeding 4x4 (16 square feet),
- Vendor must provide flame certification
- Vendor must provide a minimum size 2A10BC fire extinguisher (5 pound extinguisher)
- No combustibles are permitted under the structure (rugs, carpet, furniture:
unless flame retardant certificate re provide or they are made of metal)

Two story structures with roof:

- Vendor must provide plans of the structure which will be reviewed by Fire and Building
- Review fees may apply with Building.
- Vendor must provide flame certification
- Vendor must provide a minimum size 2A10BC fire extinguisher (5 pound extinguisher)
- No combustibles are permitted under the structure (rugs, carpet, furniture:
unless flame retardant certificate re provide or they are made of metal)

Questions:

Melissa Novak – Fire Safety Specialist

MNovak@Ontarioca.org

Office (909) 395-2559

Fax (909) 395-2585

Office Hours: Mon-Thur 7am-6pm